

CITY OF PORT WENTWORTH

7224 GA Highway 21 | Port Wentworth, Georgia 31407 Phone (912) 964-4379 | Fax (912) 966-7429 www.cityofportwentworth.com

Public Notice

ELECTED OFFICIALS

MAYOR Gary Norton

COUNCIL MEMBERS Thomas Barbee, Mayor Pro-Tem Jo Smith, At-Large P1 Gabrielle Nelson, District 1 Mark Stephens, District 2 Rufus Bright, District 3 Glenn Jones, District 4

CITY MANAGER Steve Davis For Immediate Release: July 15, 2022

RE: Sewer Overflow Reported to EPD

Date of Spill: July 14, 2022 Report Submitted: July 15, 2022 Estimated Discharge: 7,500 gallons Location: Armadale Road and Osteen Street

In the evening of 07/14/2022 During a heavy rain event, approximately 7,500 gallons of a combination of sewer water and storm water overflowed a manhole at the intersection of Armadale Road and Osteen Street in Port Wentworth GA. The overflow entered the Phillips Avenue drainage canal. The overflow occurred during a very heavy rain event when the sanitary sewer flow was impacted by the inflow and infiltration of stormwater into the sanitary sewer system overwhelming the capacity of the downstream lift station. GA EPD and the Chatham County Health Department were notified per State guidelines. Please contact Port Wentworth Public Works with any questions: 912-966-7427 or City Hall at 912-964-4379

Sincerely,

Omar Senati-Martinez, CFM Director of Public Works City of Port Wentworth, Georgia